



# Prüfzentrum für Bauelemente

Yapı Elemanları Test Enstitüsü

Kapılar · doors  
Kepenler · shutters  
Pencereler · windows  
Cepheler · curtain walling  
Yapı Donanımları · building hardware

## Letter of Result

The tests requested by the customer were carried out according to the standards below.

<b>Applicant</b>	Eliz Cam Sistemleri Sarıçam Sk. No:62 Siteler - Ankara
<b>Type</b>	Conservatory roof system, Aluminum, Laminated glazing
<b>System</b>	Wingar Tech - 10 degrees
<b>Test Date</b>	26.02.2020
<b>Dimension</b>	Total visible dimensions (W x H) max. 3400 mm x 2900 mm
<b>Results</b>	EN 12833 Resistance to snow load <b>75 Kg/m<sup>2</sup></b>

This Letter is not a certificate for CE-marking.

**PfB**  
Prüfzentrum Für Bauelemente  
Yapı Elemanları Test Merkezi San. ve Tic. Ltd. Şti.  
10045 Sokak No: 7 A.O.S.B. Çiğli / İZMİR  
Tel: (0.232) 328 10 44  
Çiğli Vergi Dairesi - 729 050 7072

Nedret Surmeli  
General Maneger