

Classification Report

Number	22-001183-PR02 (NW-A01-02-en-01)
Owner	Eliz Cam Metal Mob. Aks. San. Tic. Ltd. Sti. Önder mah. Karpuzlu 1 Cad. Siteler Ankara Turkey
Product	Triple sash sliding element with lateral side-hung window
Designation	System: FOLD TERM 211 Shipping name: DOUBLE GLASS FOLDING SYSTEM
Details	Manufacturer Eliz Cam Metal Mob. Aks. San. Tic. Ltd. Sti., - Ankara; Material Aluminium; Type of opening Turn and Slide; Opening direction DIN right, inward opening and Sliding; Overall dimensions (W x H) 2500 mm x 1700 mm
Special features	Test sequence. Position of locking. The vapour pressure equalisation of the glazing rebate has to be ensured. Mate- rial compatibility must be taken into account. Material dura- bility must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately. The country-spe- cific limitation of deflection at wind load has to be consid- ered.

Result **)

Air permeability according to EN 12207:2016-12



Class: 3

Resistance to wind load according to EN 12210:2016-03



Class: A2

Watertightness according to EN 12208:1999-11



Class: 7A

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim
04.05.2022



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 22-001183-PR02 PB-
A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: B55-80A38