

Classification Report

Number	22-001183-PR01 (NW-A01-02-en-01)
Owner	Eliz Cam Metal Mob. Aks. San. Tic. Ltd. Sti. Önder mah. Karpuzlu 1 Cad. Sitaler Ankara Turkey
Product	Combined window element composed of double sash vertical sliding window and single casement bottom-hung window at bottom
Designation	System: GIOPLUS Shipping name: DOUBLE GLASS AUTOMATIC GIULLOTINE SYSTEM
Details	Manufacturer Eliz Cam Metal Mob. Aks. San. Tic. Ltd. Sti., - Ankara; Material Aluminium; Type of opening Tilt and slide; Opening direction Inwards and down; Overall dimensions (W x H) 3500 mm x 3000 mm
Special features	Test sequence. Position of locking. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account. The strength, durability and material compatibility of the adhesive system was not part of the test and is tested separately. The country-specific limitation of deflection at wind load has to be considered.

Result **)

Air permeability according to EN 12207:2016-12



Class: 3

Resistance to wind load according to EN 12210:2016-03



Class: A1

Watertightness according to EN 12208:1999-11




Class: 6A

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim

27.04.2022



Robert Kolacny, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 22-001183-PR01 PB-A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: A1C-F1CF5