



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows
Rollläden · shutters
Türen + Tore · doors
Fassaden · curtain walling
Baubeschläge · building hardware


TEST CERTIFICATE NO. 18/10-A007-Z2

PfB-Internal-No. 2019-27-0755

Version 1.en

Testing of balcony glazing with reference to the test standards EN 1026 for air permeability, EN 1027 for water tightness, EN 12211 for resistance to wind load"

Applicant Eliz Cam Sistemleri.
Sarıçam Sokak No:62
Siteler - Ankara
Türkiye






Product type Vertical-Travel guillotine window, with one fixed and two sliding panels parts vertically controlled by electric drive, Aluminum, single glazing

Product name Giotech 300

Sealing Brush and rubber sealing

Dimension Total outside dimensions (W x H) max. 3000 mm x 2600 mm

Classification According to test report No. 18/10-A007-B2 from June 03, 2019:

	EN 1026	Air Permeability	EN 12207	Class 2
	EN 1027	Water tightness	EN 12208	Class 3A
	EN 12211	Resistance to wind load	EN 12210	Class n.p.d.

Validity Period of validity of EN 14351-1 : 2006 + A2 : 2016


Dipl. Ing. (FH) Rüdiger Müller
Head of Institute



Stephanskirchen
June 03, 2019


Yiğit Altuğ
Responsible Official