



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster · windows
 Rollläden · shutters
 Türen + Tore · doors
 Fassaden · curtain walling
 Baubeschläge · building hardware


TEST CERTIFICATE NO. 18/10-A007-Z1

PfB-Internal-No. 2019-27-0755

Version 1.en

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A2 : 2016 “Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets– German version EN 14351-1:2006 + A2:2016”

Applicant Eliz Cam Sistemleri.
 Sarıçam Sokak No:62
 Siteler - Ankara
 Türkiye



Product type Four sash sliding window , Aluminum, Double glazing

Product name Slideterm 411

Sealing Brush, rubber and Q-Ion sealing

Dimension Total outside dimensions (W x H) max. 3200 mm x 1600 mm

Classification According to test report No. 18/10-A007-B1 from June 03, 2019:



EN 1026	Air Permeability	EN 12207	Class 3
EN 1027	Water tightness	EN 12208	Class 4A
EN 12211	Resistance to wind load	EN 12210	Class C1/B1

Validity Period of validity of EN 14351-1 : 2006 + A2 : 2016

Dipl.-Ing. (FH) Rüdiger Müller
 Head of Institute

Stephan Kriehen
 June 03, 2019

Yiğit Altuğ
 Responsible Official