



Prüfzentrum für Bauelemente

Yapı Elemanları Test Enstitüsü

Kapılar · doors
Kepenler · shutters
Pencereler · windows
Cepheler · curtain walling
Yapı Donanımları · building hardware

Letter of Result

The tests requested by the customer were carried out according to the standards below.

Applicant	Eliz Cam Sistemleri Sarıçam Sk. No:62 Siteler - Ankara		
Type	Conservatory roof system, Aluminum, Laminated glazing		
System	Wingar Tech - Steel profile reinforced – 5 degrees		
Test Date	26.02.2020		
Dimension	Total visible dimensions (W x H)	max. 3400 mm x 3400 mm	
Results	EN 1026 Air Permeability	EN 12207	Class 4
	EN 1027 Water tightness	EN 12208	Class 6A
	EN 12833 Resistance to snow load		75 Kg/m ²

This Letter is not a certificate for CE-marking.

PfB
Prüfzentrum Für Bauelemente
Yapı Elemanları Test Merkezi San. ve Tic. Ltd. Şti.
10045 Sokak No: 7 A.O.S.B. Çiğli / İZMİR
Tel: (0.232) 328 10 44
Çiğli Vergi Dairesi - 729 050 7072

Nedret Surmeli
General Manager